



The world's largest producer of copper tube.

WARRANTY

SPK – Hailiang Copper Tube to NZS3501.

Hailiang Copper Tube supplied by SPK Industries Ltd complies with
NZS3501:1976 LIC # 2650



The New Zealand Standard NZS3501:1976 outlines the specification of copper tube for Water, Gas and Sanitation. The process of manufacture, chemical composition, dimensions, wall thickness, temper, hydrostatic test pressures and markings are also prescribed.

Copper Tube marked with NZS3501 LIC 2650 supplied by SPK Industries Ltd meets all the requirements of the standard.

SPK Industries Ltd and Hailiang Copper Processing Group warrant all tube marked with the relevant standard as complying with that standard, for the period of 50 years or as required by the New Zealand Building Code B2:Durability, as long as the SPK Industries limitations detailed below and installation instructions are followed as laid out in the SPK Industries technical documentation.

SPK Industries or Hailiang Copper Processing Group is unable to warrant in any way the following aspects of any copper installation.

- Workmanship and or installation practises.
- The environment in which the tube is installed.
- The system of which the tube is a part.
- Against corrosive liquids which may be transported by or stored within the tube.
- Or the effect that any of the above aspects may have on the tube.

SPK Industries discourages the use of copper tube for the reticulation of untreated / unsanitised water such as tank water or bore water, due to the possibility of unexplained microbiologically induced cold water pitting corrosion occurring, we discourage this application until a time when cold water pitting is fully understood by leading authorities.